

**WINDSOR DPW FUEL STATION IMPROVEMENTS**  
**WINDSOR, CT**  
**RFP E2020-08**

**ADDENDUM NO.1**  
**November 12, 2020**

**ADDITIONS AND REPLACEMENTS:**

None.

**QUESTIONS FROM CONSULTANTS AND CORRESPONDING ANSWERS:**

1. The project start date under bullet point 7, under Organization and Content is January 1, 2020. We presume it should be January 1, 2021?  
**Yes.**
2. Is the “road diet expertise” in the first paragraph under “8. Consultant Selection Process” correct?  
**Typo.**
3. Can the existing canopy, islands, dispensers be utilized as temporary fueling facility during construction? That of course means that the new islands, dispensers, and canopy would be built at a location slightly different from the existing. Is that acceptable?  
**Alternatives that may facilitate fueling during construction and/or deliver a more efficient project will be considered. Any viable alternative shall not significantly impact the daily operation of public works, or the other entities that utilize the fuel system.**
4. Can the temporary fuel tanks be of smaller size than the existing and the proposed, and above ground?  
**Alternatives that may facilitate fueling during construction and/or deliver a more efficient project will be considered. The size must not create a hardship, or involve additional cost, from the fuel supplier.**
5. Please comment if the Town is interested in the following elements.
  - a. New Canopy  
**Yes**
  - b. New Fuel Dispensers  
**Yes**
  - c. Aboveground storage tank in lieu of underground storage tank  
**No. Underground tanks only.**
  - d. Key card access for refueling  
**Yes**

e. New automatic tank gauge (Veeder root or other)

**Yes**

6. Are there planned construction start/completion dates?

**The existing tanks are required to be removed by June 2022. It is the assumption that summer construction when bus fueling demand is lowest would be an opportune time period for the work.**

7. Should the construction inspection be full time or part time?

**Qualifications associated with construction inspection services should be provided, but is not required. Fee proposal should not include inspection services given that the construction period and degree of inspection are unknown at this time.**

#### **Attachments**

**None.**

END OF ADDENDUM