

TEST RESULTS SUMMARY

**AFFF Spill Sampling Data
Total PFAS & Specific Compounds Detected
June 21, 2019**

6-21-19

Sample I.D.:	Upstream	Outfall	Downstream-1	Downstream-2
Total PFAS Detected (ng/L [ppt])	17.94	330.82	49.85	39.74
NETFOSAA	< 0.86	< 0.88	< 0.88	< 0.9
Perfluorobutanesulfonic acid	1.4	1.3	1.2	1.2
Perfluorobutanoic acid	1.9	3.1	2.1	2.1
Pefluorodecanesulfonic acid	< 0.52	0.75	< 0.53	< 0.54
Perfluorododecanoic acid	< 0.43	1.4	< 0.44	< 0.45
Pefluoroheptanesulfonic acid	< 0.34	1.0	< 0.35	< 0.36
Pefluoroheptanoic acid	0.95	1.3	1.2	1.1
Pefluorohexanesulfonic acid	1.4	4.4	2.1	1.8
Pefluorohexanoic acid	2.2	3.5	2.6	2.4
Pefluorononanesulfonic acid	< 0.52	1.6	< 0.53	< 0.54
Pefluorononanoic acid	0.49	1.2	0.65	0.64
Pefluorooctanesulfonamide	< 0.43	1.9	< 0.44	< 0.45
Pefluorooctanesulfonic acid	4.6	300	35	25
Pefluorooctanoic acid	2.7	4.5	2.7	2.7
Pefluoropentanesulfonate	< 0.34	0.61	< 0.35	0.4
Pefluoropentanoic acid	2.3	2.3	2.3	2.4
Perfluorotetradecanoic acid	< 0.26	0.66	< 0.26	< 0.27
Perfluoroundecanoic acid	< 0.34	1.3	< 0.35	< 0.36
Total PFAS Detected June 9, 2019	37.72	1,515,700	13,330	10,253
Total PFAS Detected June 11, 2019	--	90,899.4	--	--



Environmental Services, Inc.