



NOTES:

1. BACKFILL TRENCH WITH APPROVED FLOWABLE FILL. THE FLOWABLE FILL SHALL FLOW UNDER AND AROUND PIPE OR CONDUIT, PROVIDING UNIFORM SUPPORT WITHOUT VOIDS.
2. THE FLOWABLE FILL SHALL HAVE A MAXIMUM COMPRESSIVE STRENGTH OF 100 PSI.
3. THE CONTRACTOR SHALL SUBMIT THE FLOWABLE FILL MIX DESIGN FOR REVIEW PRIOR TO PLACEMENT.
4. THE FLOWABLE FILL MUST BE EXCAVATABLE WITHOUT THE USE OF POWER TOOLS.
5. BRING FLOWABLE FILL TO WITHIN 4" (MAX.) OF FINISHED GRADE.
6. PROVIDE A MINIMUM CURING TIME OF 8 HOURS PRIOR TO INSTALLATION OF BITUMINOUS CONCRETE PAVEMENT.



TOWN OF WINDSOR
Engineering Department



FLOWABLE FILL
TRENCH REPAIR



SCALE: $\frac{\text{HOR.}}{\text{VER.}}$ NTS _____ DATE: OCTOBER 2012