



NOTES:

1. CONCRETE SHALL BE MINIMUM 4,000 PSI, 28 DAY
2. CONDUIT SHALL BE SCHEDULE 40 PVC.

A	B	CHAMFER	AREA TO BE USED	BOLT CIRCLE DIAMETER
15"SQ	20"SQ MIN.	3/4"	RESIDENTIAL/DECORATIVE	12 3/8"
20"SQ	24"SQ MIN.	1"	COMMERCIAL/INDUSTRIAL	15"



TOWN OF WINDSOR
Engineering Department



CONCRETE LIGHT
STANDARD BASE
D-403



SCALE: $\frac{\text{HOR. NTS}}{\text{VER.}}$ DATE: MAY 2010