

NOTES:

- 1. SUITABLE FILL AND PROCESSED AGGREGATE BASE SHALL BE COMPACTED 95% PER AASHTO T-180 METHOD 'D'.
- 2. IF GREATER THAN 5 LINEAR FEET OF EXISTING PAVEMENT MARKINGS HAVE BEEN REMOVED THEN THE PAVEMENT MARKINGS SHALL BE REPLACED WITH EITHER HOT—APPLIED OR EPOXY RESIN PAVEMENT MARKINGS TO MATCH EXISTING CONDITIONS.
- 3. SUPERPAVE MAY BE USED IN PLACE OF CLASS 1 AND CLASS 2 BITUMINOUS CONCRETE WITH THE APPROVAL OF THE TOWN ENGINEER.



TOWN OF WINDSOR Engineering Department



BITUMINOUS CONCRETE
PAVEMENT REPAIRS
D-203

S

SCALE: HOR. NTS

- DATE: JUNE 2016