



NOTES:

1. MINIMUM LENGTH OF GRANITE CURB SHALL BE 4'-0".
2. GRANITE CURB FINISH SHALL BE SAWN TOP & SPLIT FACE JOINTED.
3. GRANITE CURB WITH A RADIUS OF 100' OR LESS SHALL BE BUILT OF CURVED GRANITE CURB.
4. CLASS "C" CONCRETE SHALL BE PROVIDED AS BACK SUPPORT TO FILL JOINT OPENING OF GRANITE CURBING AND AS BACK SUPPORT THROUGHOUT CURVED GRANITE.
5. MORTAR OR OTHER APPROVED FILLER SHALL BE USED IN ALL JOINTS FOR GRANITE CURBING.



TOWN OF WINDSOR
Engineering Department



MEDIAN DETAIL
D-208



SCALE: $\frac{\text{HOR. NTS}}{\text{VER. NTS}}$ DATE: AUGUST 2010