



SEE TYPICAL PAVEMENT SECTION FOR LOCATION OF PIPES.

NOTES:

1. ALL CONCRETE PIPE TO BE MINIMUM CLASS IV UNLESS OTHERWISE SPECIFIED.
2. USE WATERTIGHT GASKETS IN ALL PIPE JOINTS.



TOWN OF WINDSOR  
Engineering Department



DRAINAGE TRENCH  
D-300



SCALE:  $\frac{\text{HOR. NTS}}{\text{VER.}}$  DATE: MAY 2010