

DPW FUEL STATION EQUIPMENT
WINDSOR, CT
RFP E2021-09

ADDENDUM NO. 1

August 11, 2021

QUESTIONS FROM CONTRACTORS/SUBCONTRACTORS AND CORRESPONDING ANSWERS:

Question 1: *Is this ONLY for supplying the equipment (not the installation)?*

Yes, this is only for supplying and storing the equipment until needed.

Question 2: *Is there a contract coming out for the installation of this site?*

Yes, there will be a contract for the installation at a later date.

Question 3: *Will there be a bid walkthrough?*

No, there will not be a bid walkthrough for this contract.

Question 4: *Is it acceptable to provide a substitute for the Wayne dispensers and Fuel management system*

No, substitutions for dispensers and fuel management system will not be considered.

Question 5: *The tank specs reference a tank drawing. Are there any drawings for this bid?*

Drawings are not needed for completion of this bid. Tanks shall be 8' diameter, double wall, fiberglass with brine filled annular.

Attachments: **None.**