SALAMONE & ASSOCIATES, P.C.

Consulting Engineers

116 North Plains Industrial Rd • Wallingford • CT • 06492 • Phone (203) 281-6895 • Fax (203) 287-8728

ADDENDUM NO. 1

TO THE

CONTRACT DRAWINGS AND SPECIFICATIONS

FOR HVAC RENOVATION PROJECT PHASE II AT SAGE PARK MIDDLE SCHOOL WINDSOR, CT

This addendum issued on February 4, 2022 shall form part of the Contract Documents dated January 17, 2022 and modifies the Contract Drawings and Specifications. The bidder shall acknowledge receipt of this addendum in the space provided on the bid form. Failure to do so may subject the bidder to disqualification. This addendum consists of Five (5) pages.

I. <u>GENERAL:</u>

1. Bids will be received at the Finance Department Windsor Town Hall Attn: Director of Finance James Bourke Windsor Town Hall 275 Broad Street, Windsor, CT 06095 until Thursday February 10, 11:00 AM at which time they will be opened in the Windsor Town Hall via Zoom Meeting to be scheduled.

II. MECHANICAL CLARIFICATIONS:

- 1. Provide heavy duty exterior enclosures for all refrigeration line sets and condensate piping. Enclosures shall be equal to Slim Duct by RectorSeal. Color by Owner.
- 2. Provide condensate piping from each indoor AC unit. Condensate piping shall be routed to the exterior enclosures.
- 3. Route all refrigerate piping from indoor AC unit to labeled exterior heat pump unit as required. See Speciation Section 15760 for piping and insulation requirements.
- 4. Drawing DME-1: Existing RHC-3 shall remain in place.
- 5. Drawing DME-1: Existing control valves for RHC-1, RHC-2, RHC-3 and RHC-4 shall remain in place.
- 6. Drawing ME-1: Existing RHC-1 is no longer required to be replaced.
- 7. Drawing ME-1: Existing control valves for RHC-1, RHC-2, RCH-3 and RHC-4 are no longer required to be replaced.

Page 1 of 2

SALAMONE & ASSOCIATES, P.C. Consulting Engineers


116 North Plains Industrial Rd • Wallingford • CT • 06492 • Phone (203) 281-6895 • Fax (203) 287-8728


- 8. Drawing ME-3: Contractor shall provide a condensate pump and piping for AHU-1, AHU-S8 and AHU-S9. Pump shall be equal to little giant model VCMA-15ULS. Route condensate piping to nearest sanitary.
- 9. Remove drawings ME-6, ME-7 and ME-8.
- 10. Add drawings ME-6, ME-7 and ME-8 attached.
- Specification Section 15870 Power Ventilators, 2.4 Centrifugal Roof Ventilators,
 E. Accessories: Remove 1. Disconnect Switch: Nonfusible type, with thermal overload protection mounted inside fan housing, factory-wired through an internal aluminum conduit. Provide fused disconnect as indicated on drawings.


III. ELECTRICAL CLARIFICATIONS:

- 1. Contractor shall provide a duplex receptacle for AHU-1's condensate pump. Coordinate location in field with Div. 23. Provide 3 /4"C, 2-#12 AWG + #12 GND for connection to line side of proposed GFCI receptacle circuit DP-AC10/20.
- 2. Contractor shall provide a single receptacle for condensate pump within each of the two mechanical rooms serving AHU-S8 and AHU-S9. Coordinate location of respective receptacle for each AHU in field with Div. 23. Provide 3 /4"C, 2-#12 AWG + #12 GND for connection to line side of 120V circuit serving the respective AHU's circulator pump within each respective mechanical room. Connection point shall be upstream of circulator pump local disconnect switch. Typical.

END OF ADDENDUM NO. 1







PARTIAL MECHANICAL/ELECTRICAL SECOND FLOOR PLAN WING "D" SCALE: 1/8"=1'-0"

