



ADDENDUM #5

Date: March 25, 2024

Oliver Ellsworth Humidity Mitigation **730 Kennedy Rd, Windsor, CT 06095**

1. Delete addendum # 4 - Response to RFIs - item # 6 in its entirety and replace as follows:

a. Question: Please confirm that there are no modifications to the existing FCU's.

Answer: No modifications to the existing FCU's are required.

2. Provide an add alternate price for the following scope of work in regard to the Unit Ventilators (UV) with outside air and dampers:

Scope of work for UV: Remove damper actuator and safe-off any unused wire. Lock damper to full return air position. Return actuator to owner. Modify sequence of operation and graphics, as necessary, to control and operate UV without outside air damper.

Attached is revised Proposal Sheet.

Oliver Ellsworth Humidity Mitigation

Proposal Sheet

Town of Windsor

Windsor Town Hall, Finance Department, 275 Broad Street, Windsor, Connecticut 06095

TO: Mr. James Bourke
Director of Finance
Town of Windsor
275 Broad Street
Windsor, CT 06095

The undersigned _____ doing business in the
Town of _____, County of _____, State of _____,
submits herewith, in conformity with the RFP dated February 26, 2024, the following proposal.

PROPOSAL LUMP SUM BID

\$ _____
(_____)
Written Amount

ADD ALTERNATE # 1

\$ _____
(_____)
Written Amount

Name of Bidder: _____

By: _____

Title: _____

Address of Bidder: _____

Telephone No.: _____

Email: _____